

### Calculation Checklist

This checklist shall be used to record the site data and calculate the Hydro Abstraction Factor for the site ( $HAF_{site}$ ) to allow conversion of electrical output to quantities abstracted. **The  $HAF_{site}$  is the amount of water used in  $m^3$  per kWhr generated for any period.**

Site Data	
Site name	Hafod y Rhedrywdd micro-hydro
Address	Hafod y Rhedrywdd, Cwm Penmachno, LL24 0RF
Licence serial No.	
Contact name	Dr R.W.Moss
Contact telephone	07854 675742
Contact email	roger@rwmoss.co.uk
Turbine manufacturer	Hartvigsen Hydro
Turbine type	Turgo
Turbine serial no.	
Number of jets <small>(where relevant)</small>	1 large, 1 small per turbine (two turbines = 1 main plus 1 low power)

Performance Data		
Parameter	Value	How was the parameter determined?
Net operating head of the system at maximum power output ( $H_n (P_{max})$ ) in metres	112.8 m (126.5 m)	Absolute maximum power would be 9.06 kW (net) at 14.2 litres/second. This is probably not a sensible operating condition due to the fall-off in rpm when losing 1/3 of the head to friction – it does not give a sensible measure of typical system efficiency (see HyR proposal v13.pdf, Figure 14). 8.8 kW (at 12.14 litres/sec) is a more sensible “maximum” operating point for both turbines running together. For completeness I am also including the maximum power from just the main turbine, 7.88 kW at 9.6 litres/sec. “Values” are at <b>8.8 kW (7.88 kW)</b> .
Turbine/water wheel efficiency at maximum power output ( $e_{turbine/water\ wheel} (P_{max})$ )	0.824 (0.826)	Manufacturer’s spreadsheet (83%) less 44 W estimate of bearing and windage losses based on formulae in Thake’s <i>Pelton design handbook</i> .
Transmission system efficiency at maximum power output ( $e_{transmission} (P_{max})$ )	0.843 (0.846)	Result of 4.4% losses due to cable resistance and alternator cooling fans, 150 W control system power consumption and 90% (combined) rectifier and inverter efficiency. See <i>system_perf8.m</i> lines 106-125 for the actual calculation and <i>system_plot4.m</i> for the output display
Generator efficiency at maximum power output ( $e_{generator} (P_{max})$ )	0.943 (0.947)	Manufacturer’s data sheet (MOOG GES013 alternators).

### Calculation of overall system efficiency of the rotating parts of the hydro system, at maximum power output ( $e_{system} (P_{max})$ )

$$e_{system} (P_{max}) = e_{turbine/water\ wheel} (P_{max}) \times e_{transmission} (P_{max}) \times e_{generator} (P_{max})$$

$$= \boxed{0.824} \times \boxed{0.843} \times \boxed{0.943}$$

$$e_{system} (P_{max}) = \boxed{0.655 (0.662)}$$

### Calculation of $HAF_{site}$

$HAF_{site}$  = Hydro Abstraction Factor for the site in question

Where:

$H_n (P_{max})$  = net head at max. power.

366.972 = a constant in order to bring the final HAF into the correct unit of  $m^3/kWhr$  (it is arrived at by dividing the number of seconds in an hour (3600) by gravity (9.81  $m/s^2$ ))

$$\begin{aligned}
 &= 366.972 / ( H_n (P_{max}) \times e_{system (P_{max})} ) \\
 &= 366.972 / ( \boxed{112.8} \times \boxed{0.655} ) \\
 &= \boxed{4.97 (4.38)} \quad (\mathbf{m3/kWh})
 \end{aligned}$$

The volume of water abstracted for any period ( $V_{period}$ ) can then be calculated by simply multiplying the  $HAF_{site}$  by the number of kiloWatt hours generated thus:

$$V_{period} (m3) = kWh_{period} (kWh) \times HAF_{site} (m3/kWh)$$

The minimum HAF is 3.806 m<sup>3</sup>/kWh for the small alternator at 2.7 litres/sec.

